

Agility Care Integrity Excellence Collaboration Trust Respect



Urban Rooftop PV Projects

3rd April 2012







Renewable Energy Portfolio of Tata Power



TATA POWER Lighting up Lives!







60 kW Solar PV at Carnac - Commissioned





Purpose	- Contribute to achieving Solar RPO requirement of Tata					
	Power- D					
	- Pilot project to evaluate the feasibility of utilising the					
	rooftops of Commercial and Industrial establishments					







TATA POWER Lighting up Lives!

Λ

Number of panels	336 (28 arrays each containing 12 modules or panels)		
Size of each panel	1587 mm x 790 mm		
Area occupied	549 m ²		
Generation Level	35.8 V (at P _{max})		

Output Voltage	400 volts three phase, 4 wire, grid tracking			
Nominal voltage adjustment	<u>+</u> 5% via system set points			
Output Frequency	50 Hz <u>+</u> 0.5%			
Inverter to follow grid	upto <u>+</u> 3Hz of the nominal output frequency			
frequency				
Continuous Rating	60kVA with all phase equally loaded			
Efficiency	94%			







Stand for Connectivity of the Project



Which is right place to connect ?

➤ Regulation 2.1 (cc) of MERC (RE Tariff) Regulations, 2010,

"'Solar rooftop PV and other small solar power' means the Solar rooftop or other small solar Photo Voltaic power projects that uses Photo Voltaic technology for generation of electricity, which are mounted on rooftop of buildings or ground mounted installations, and satisfying any other eligibility criteria as may be specified by MNRE from time to time."

- Appropriate location Carnac Rooftop and nearest connectivity at 415 V station auxiliary bus of Tata Power-T at Carnac Receiving Station
- Carnac Receiving Station and 415 V station auxiliary bus of Tata Power-T part of Tata Power-T assets

Issues Faced – Grant of Connectivity



- MERC (State Grid Code) Regulations, 2006 states as under,
 - "13.1 Application for establishing new arrangement or modifying existing arrangement of connection to and/or use of the InSTS shall be submitted by the concerned Transmission Licensee or User to the State Transmission Utility:

Provided that the standard format for application mentioned in the Regulation 13.1 shall be developed by State Transmission Utility and shall be made available at its Internet website within two (2) months of notification of these Regulations."

- Accordingly, Tata Power-Solar made an application to the STU for grant of connection for 60.48 kWp Rooftop Solar PV Project.
- STU replied as under,

"... The Open Access sought by you is for load/generation less than 1 MW. As per MERC's Open Access Regulation, there are no guidelines for granting Open Access for load/generation less than 1 MW.

Hence, you are requested to take up the matter with Hon. MERC for necessary guidelines."

Extracts of MERC Order



- CEA is in a process of initiating expert consultation to formulate and notify grid connectivity standards and regulations, which shall govern connectivity related aspects for such distributed generation sources
- The nearest distribution s/s of BEST is around 0.5 km away from the project. This prima facie shows the <u>non-availability of any Distribution network in the proximity of the project</u>. This has led Tata Power-T to connect the project to its own Receiving Station, which is a part of the Tata Power-T asset and on the Rooftop of which, the Project is installed
- In view of the above, the Commission recognises that this project needs to be treated as unique case and the issues raised need to be addressed, particularly in view of the fact that as per Section 86(1)(e) of Electricity Act 2003, the Commission is mandated to promote generation from renewable sources of energy by inter alia providing suitable measures for connectivity with the grid.



Agility Care Integrity Excellence Collaboration Trust Respect

500 kW Solar PV at Tata Motors



Location of the Project



Location	Capacity
Block D of Tata Motors, Pimpri	100 kWp
Block E of Tata Motors, Pimpri	300 kWp
Block H of Tata Motors, Pimpri	100 kWp

Advantages of the Project:

- Pioneer a case for use of rooftops of large industrial premises for renewable energy generation which can be replicated
- Generate electricity from renewable sources

10

Meet RPO obligations of the distribution licensees



Tata Motors - Present Electrical Set





- Tata Motors is fed by 220 kV MSETCL R/s situated in North West side of the premises
- Tata Motors have laid 220kV cable within its premise to feed its own 220kV /22 kV S/s
- S/s consists of 2 no. of 30 MVA 220/22 kV transformers and a 40 MVA 220/22 kV transformer. Installed capacity of 100 MVA
- Revenue metering arrangement at 220 kV level
- The 22kV outgoing feeders from the Tata Motor's S/s feeds the 3 Nos Main Receiving station (MRS) located at different places
- MRSs feed the different blocks. Within each block , there are 2 MVA 22kv /440 V Transformers which feed the different loads within each block.

MERC RE Tariff Regulations, 2010



Regulation 2.1 (p) of MERC (RE Tariff) Regulations, 2010 defines Inter- connection Point as follows:

"Inter-connection Point shall mean <u>interface point of renewable energy generating</u> <u>facility with the transmission system or distribution system</u>, as the case may be:

1. in relation to wind energy projects and Solar Photovoltaic Projects, inter-connection point shall be the line isolator on outgoing feeder on HV side of the pooling substation..... "

Interconnection to Transmission System



TATA POWER Lighting up Lives!

Interconnection to Distribution System





14

Advantages Inter-Connection is as per MERC (RE Tariff) Regulations, 2010 **High Capital Cost** Disadvantages There may be right of way issues for laying a line of 3 Km. Further in our humble submission, a line length of 3 km is high for a 500 kW power plant Space availability for an additional bay at MSEDCL Akurdi Sub-station may be a constraint Long lead time to establish this setup

Interconnection Cost – Rs. 215 lakhs



Financial Impact of the options



Scenario Summary		Tata Motors System (<i>Base Case)</i>	Transmission Network	Distribution Network
Capital Cost	Rs. in Lakhs	845	1425	1025
Impact on Pre-Tax RoE	%	19%	5%	13%



Proposed Metering Arrangement



- MSEDCL shall record the meter reading at the revenue meter for Tata Motors, which shall be a net meter reading (A)
- MSEDCL shall also record meter reading for the proposed Roof top Solar PV (Generation Meter) (B)
- Bill of Tata Motors for power supplied by MSEDCL shall be the aggregate of meter reading at revenue meter and meter reading at Generation Meter – (A) + (B)
- MSEDCL shall provide credit of the entire energy recorded at the meter to TPREL and shall not apply wheeling charges & losses as the inter-connection is to the consumer's system and then to the transmission system

TATA POWER Lighting up Lives!

17

Issues are with respect to connectivity & separate metering arrangement

Preliminary Views of the stakeholders



Tata Power

•The connections though not on basis of the present practice is not incorrect. •It involves adjustment of energy

MSEDCL

•This is not a normal connection practice. It will involve taking meter reading of Solar Plant which is inside the premises

<u>SLDC</u>

•The norms for connections has to be established else every solar plant would like to get connected his own way

MERC

•This seems to be an offgrid connections. We may have to wait for guidelines for connectivity develop on the same



18

Issues are with respect to connectivity & separate metering arrangement



Agility Care Integrity Excellence Collaboration Trust Respect

Summary of Issues



Summary of the Issues



Connectivity to the Grid

- Most of the rooftop in urban area are smaller in size
- Smaller rooftop would entail Solar PV projects of smaller capacity
- It would not be economically feasible to connect these projects to the 11 kV or 33 kV network using a separate step-up transformer
- Policies need to be framed to allow these projects to directly connect with the grid (like a net metering system allowed in many countries) while ensuring the adequate safety of the grid and the system

Monitoring & Metering of the smaller system

20

Proper mechanism for monitoring and metering the smaller systems need to be established but should not be an hindrance in the promotion of Rooftop Solar



"Journey Continues.. We value your inputs, suggestions and critique."

We take pride in Lighting up Lives!